


Installation Monitoring Report

Project	NW 2050 Cypress Point	Job Number	24064	RGC Number		N/A	
Address	7511, 7531, 7651 Minoru Boulevard	Inspector	Matthew	Report Number		06	
	Richmond, B.C.	Weather	Sun / 15°C	Time		1:30pm	
Contractor	Flynn Canada Ltd.	Crew Size	9 Red Seal	3	Apprent	ices	5

Date: May 20, 2025

Distribution List: keith.lodge@flynncompanies.com, ken.brown@flynncompanies.com, nw2050@telus.net. matt@phoenixroofconsultants.ca



6.1 **Building B**

The remaining sections of the main roof on the South end, are receiving the Soprema 2n1 smart board sanded with ½" HD.




6.2 **Building B**

A 2" barbed seam plate is being installed 2" on center and secured with 2" #14 dek fast screws 12" O.C.



6.3 **Building B**

Foreman indicated that one section of plywood was replaced due to section being broken. No deterioration reported in other cut tests.



6.4 **Building B**

Additional curb build up to occur on the three of the duct work sides to match the height already pre-existing against the parapet.




6.5 **Building B**

Sopraply Stick DUO and Soprema Lastobond HT are being rolled into a Elastocol 500 primed surface of the Densdek prime applied to the surface.



6.6 **Building B**

Heat welding of seams in progress on the base layer of the roof.



6.7 **Building B**

An additional 3/4" build up required at the East end of the building at the South parapet to mitigate ponding water occurring at that location.


The use of ¼" Sopraboard and Sopraply stick DUO to be used to create a cricket.



6.8 **Building B**

Rubber pavers and final organic cleanup have occurred on Unit 325 deck area. Membrane applications will likely occur shortly.





Outstanding Items:

• None currently.

Reported by:

Matthew Blackstock, RRO Phoenix Roof Consultants

Phoenix Roof Consultants field reviews are for general conformance to specifications and roofing compliance only. Our reviews are not to take the place of the contractor's own quality control which shall remain the responsibility of the contractor. Phoenix Roof Consultants will not be responsible for acts or omissions of the contractor or for the contractor's failure to fulfill the intent of the specifications, contract, or quote.